

PLD-MP801/25/2-5 - Attachment 1

Transformer

Brand	KVA	PT No.	TP No.	SR No.	Hazardous oil (kg)	Year
Efacec	1000	752	1205	11182.2	400	1989
Elvim	1000	1603	2210	060642	795	2006
Fortune Electric	1600	771	1768	D990041	728	1999
Gecalsthom	630	839	1221	109507	319	1991
Gecalsthom	1000	883	1212	109493	502	1991
Gecalsthom	1000	799	1123	797799	538	1990
Gecalsthom	1000	742	1206	109490	502	1991
Gecalsthom	1600	607	1182	109512	728	1991
Gecalsthom	1600	594	1180	109480	728	1991
Gecalsthom	1600	607	1183	109522	728	1991
Siemens	630	590	1053	LEL36008	314	1990
Siemens	1000	672	992	LEL32526	610	1988
Siemens	1000	632	1195	LEL40988	640	1991
Siemens	1000	507	964	LEL32146	610	1988
Siemens	1000	1204	1199	LEL40992	640	1991
Volta-Werke	1600	359	828	44515	600	1987

Other Materials

DESCRIPTION		QUANTITY
1	Lanterns	1 lot
2	Lamps	1 lot
3	Lighting poles	1 lot
4	Waste cable drums	1 lot
5	LV boards-8 outgoing	4
6	LV boards-10 outgoing	5
7	LV boards-12 outgoing	2
8	Cable supports LV 630	4
9	Cable supports LV 1000	4
10	Cable supports LV 1600	6
11	Fuses from TAD/CSC/EMG (35A,63A,100A,160A,200A,250A,315A,400A)	1 lot
12	Tinned copper bar size: 3/8" X 4 X 1.2m	57

(Total: 12 items of different materials)