

#### NOTE

注意

Transformer base  
火牛基礎

All structure in HDG (Hot dip galvanized)  
所有材料用 HDG

Pit for oil drainage ( only for transformer 1000kVA or above )  
1000kVA 火牛以上要有油坑

HDG cable cover with slat  
HDG 線槽蓋要有花紋


PVC cable duct sealing  
電纜膠管防滲水

Cable gutters free of water  
線槽不得積水

All screws and expansion screws fix with rings  
安裝所有螺絲要用介子

All screws and expansion screws for earthing must be HDG  
安裝所有螺絲為地氣要用HDG

L	09/11/2006	Change the size of hole on M.V. trench cover	Hou	Tavares	Tavares
K	13/07/2006	Change the size on L.V. trench	Hou	Tavares	Tavares
J	06/06/2006	Change the size on L.V. trench	Hou	Tavares	Tavares
I	20/04/2006	Change the cover on M.V. trench	Hou	Tavares	Tavares
	Date	Modification	Draft.	Verif.	Approv.

Draft.	Hou	08/02/1987	Customer Substation (P.T.) Civil Construction	
Verif.	Tavares	08/02/1987		
Approv.				
Support for Transformer Type I 變壓器底座支撐類型 I				
				TAD
Scale 1 : 40 & 1 : 8		Remarks	Job Nº	Drawing Nº D-117