



DETAIL A 詳圖 A
SCALE 1:5 比例 1:5

NOTE 注意
All structure in stainless steel 2mm thick 所有材料要用不鏽鋼2mm 厚
All structure in stainless steel of the low carbon type AISI316L 所有材料要用不鏽鋼 AISI316L
Louvers/stainless steel plates with earthing point and drainage 百葉窗有接地線耳和去水線
All screws and expansion screws fix with rings 安裝所有螺絲要用介子
All screws and expansion screws must be stainless steel 安裝所有螺絲要用不鏽鋼品種

D					
C					
B					
A					
	Date	Modification	Draft.	Verif.	Approv.

Draft.	Hou	23/11/2010	Customer Substation (P.T.) Civil Construction		
Verif.	Tavares	23/11/2010			
Approv.	Tavares	23/11/2010			
Typical details of stainless steel louver for air intake 進氣口不鏽鋼百葉的標準大樣圖				TAD	
Scale 1 : 5 & 1 : 20		Remarks		Job N ^o	Drawing N ^o D-330