



NOTE 注意
Transformer base 火牛基礎
All structure in HDG (Hot dip galvanized) 所有材料用 HDG
Pit for oil drainage (only for transformer 1000kVA or above) 1000kVA 火牛以上要有油坑
HDG cable cover with slat HDG 線槽蓋要有花紋
PVC cable duct sealing 電纜膠管防滲水
Cable gutters free of water 線槽不得積水
All screws and expansion screws fix with rings 安裝所有螺絲要用介子
All screws and expansion screws for earthing must be HDG 安裝所有螺絲為地氣要用HDG

M	13/07/2006	Change the size of hole on M.V. trench cover	Hou	Tavares	Tavares
L	13/07/2006	Change the size on L.V. trench	Hou	Tavares	Tavares
K	06/06/2006	Change the size on L.V. trench	Hou	Tavares	Tavares
J	03/03/2006	Change the cover on M.V. trench	Hou	Tavares	Tavares
	Date	Modification	Draft.	Verif.	Approv.

Draft.	Hou	11/02/1987	Customer Substation (P.T.) Civil Construction	
Verif.	Tavares	11/02/1987		
Approv.				
Support for Transformer Type II 變壓器底座支撐類型 II				TAD
Scale 1 : 40 & 1 : 8	Remarks		Job N ^o	Drawing N ^o D-119