



EXTERIOR ELEVATION
SCALE 1:40
正面
比例 1:40


INTERIOR ELEVATION
SCALE 1:40
背面
比例 1:40



SECTION B - B
SCALE 1:40
剖面 B - B
比例 1:40




DETAIL 1
SCALE 1:20
詳圖 1
比例 1:20




DETAIL 2
SCALE 1:20
詳圖 2
比例 1:20


SECTION A - A
SCALE 1:40
剖面 A - A
比例 1:40




DETAIL 3
SCALE 1:20
詳圖 3
比例 1:20




DETAIL 4
SCALE 1:20
詳圖 4
比例 1:20



DETAIL 5
SCALE 1:4
詳圖 5
比例 1:4



EXTERIOR ELEVATION
SCALE 1:20
正面
比例 1:20



SECTION 2 - 2
SCALE 1:20
剖面 2 - 2
比例 1:20

DETAIL 6
SCALE 1:4
詳圖 6
比例 1:4

SECTION 1 - 1
SCALE 1:20
剖面 1 - 1
比例 1:20

NOTE 注意
All structure in stainless steel of the low carbon type AISI316L 所有材料要用不銹鋼 AISI316L
Welding stainless steel for door 門身用不銹鋼燒焊
Stainless steel hing (ϕ 30mm) 門鉸用不銹鋼 ϕ 30mm
Stainless steel plate 2mm for doors 門身不銹鋼用 2mm 厚度
Stainless steel flat (40mm wide x 4mm thick) for doors 門身用不銹鋼扁 40mm x (闊) (厚)
Clean the door 門身清潔
All screws and expansion screws fix with rings 安裝所有螺絲要用介子
All screws and expansion screws must be stainless steel 安裝所有螺絲要用不銹鋼品種

D					
C					
B	04/03/2002	Change the CEM logo	Hou	Eddey	Kin
A	31/07/2000	Change the size of door pivot from ϕ 25mm to ϕ 30mm and the stainless steel plate from 40x2mm to 40x4mm	Hou	Wanda	
	Date	Modification	Draft.	Verif.	Approv.

Draft.	Hou	10/05/1995	Customer Substation (P.T.) Civil Construction		
Verif.	Tavares	10/05/1995			
Approv.					
Single leaf stainless steel door with louver 不鏽鋼單扇門帶百葉窗				TAD	
Scale 1 : 4, 1 : 20 & 1 : 40.		Remarks		Job N°	Drawing N° D-234